



China

CERTIFICATE

No. Z1GCN 121704 0015 Rev. 00

Holder of Certificate:

Shanghai VATTEN Valve Co., Ltd.

Minhang District

Floor 12, Building 30, Lane 160, Yinkang Road

201111 Shanghai City

PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Actuators

GVA SERIES PNEUMATIC ACTUATORS

Evaluated according to:

IEC 61508-1:2010

IEC 61508-2:2010

Certification Rule:

GCN_CCB_GR_030CS

Certification Type:

Design Assessment + Inspection + Factory inspection + Surveillance

It is certified that the product meets the requirements of certification rule and relevant normative documents. The certification marks shown above can be affixed on the product. It is not permitted to alter the certification marks in any way. In addition, the certificate holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Report no.:

7482549373-006

Valid until:

2028-07-23

Date,

2025-05-09





China

CERTIFICATE

No. Z1GCN 121704 0015 Rev. 00

Manufacturer:

Shanghai VATTEN Valve Co., Ltd.

Minhang District, Floor 12, Building 30, Lane 160, Yinkang Road, 201111

Shanghai City, PEOPLE'S REPUBLIC OF CHINA

Production

Shanghai VATTEN Valve Co., Ltd.

Facility(ies):

Minhang District, Floor 12, Building 30, Lane 160, Yinkang Road, 201111

Shanghai City, PEOPLE'S REPUBLIC OF CHINA

Brand Name:

VATTEN

Model(s):

GVA SERIES PNEUMATIC ACTUATORS

Parameters:

System type: Type A

Systematic Capability: SC3

Product Scope: Air source pressure : 2.5~8bar, Torque : MAX 172710N*M, -45°C~425°C

Safety Function Definition:

SIF: "Correct switching on demand (open to closed and closed to open), in low demand mode of operation"

Max SIL: SIL3